

PEACE RIVER MANASOTA REGIONAL WATER SUPPLY AUTHORITY

Hon. Alan Maio
Sarasota County

Hon. Elton A. Langford
DeSoto County

Hon. Bill Truex
Charlotte County

Hon. George Kruse
Manatee County

Patrick J. Lehman, P.E., Executive Director

Filter Valves with Actuators

Invitation to Bid

DATE: January 11, 2021
FROM: Chris Rogers, Project Manager
RE: Addendum #1

Addendum #1 includes:

The answer to the only question received.

Question

I am reviewing the valve schedule and need a clarification. The 12” filter influent valves are calling for an extended bonnet. Is there a drawing that shows this detail? We could need to know the measurement, from the top of the valve to the platform, where the 36” floor stand will be located.

Response:

See page 5 of Section 15101 – AWWA Butterfly Valves, dated December 2020, Section 2-6. ACCESSORIES. “...The centerline of valve to top of extension is 84 inches...” See photograph on following page of the existing valve and actuator, which is being replaced. While some flexibility is possible here, it is critical that any protrusions from the actuator body avoid impacting the guardrail system.

<end of Addendum #1>

