

1 **CONTRACT DOCUMENTS**

2
3 **FOR**

4
5 **PEACE RIVER FACILITY – TREATMENT TRAINS 5 & 6 REHABILITATION PROJECT**

6
7 **FOR**

8
9 **PEACE RIVER MANASOTA REGIONAL WATER SUPPLY AUTHORITY**

10
11
12 **ADDENDUM NO. 1**

13
14 **Date Issued: February 19, 2021**

15
16 Bidders on this project are hereby notified that Addendum No. 1 shall be attached to and made
17 part of the above-named Bid Documents, dated February 2021.

18
19 The following items are issued to add to, modify, and clarify the Bid Documents. These items
20 shall have full force and effect as the Bid Documents, and the cost involved shall be included in
21 the various prices bid. Bids, to be submitted on the specified date, shall conform to the
22 additions and revisions listed herein.

23
24 **GENERAL QUESTIONS AND CLARIFICATIONS**

- 25
- 26 1. The Engineer's estimate is \$3.97 million dollars (\$3.97 million) for this construction
27 project.
 - 28
29 2. As stated in the Instructions to Bidders, under EXPERIENCE STANDARDS, item 3.3A., the
30 Contractor must be a State-of-Florida licensed General Contractor for ten (10) years or
31 more.
 - 32
33 3. The filter basins are 15'-0" x 25'-0". Dimensions are shown on drawing S-30-101.
 - 34
35 4. Filter cell 32 was recently rebuilt and therefore replacement of the media in this cell is
36 not included in this Contract. See Note 1 on drawing M-30-301.

37
38
39 **IN THE INSTRUCTIONS TO BIDDERS**

- 40
41 1. ARTICLE 3 – QUALIFICATIONS OF BIDDERS, third paragraph under EXPERIENCE
42 STANDARDS for the Company as a whole, item C, which previously read as follows:

- 1 C. Have constructed at least ten (10) multi-media, declining rate filters with corrugated
2 metal underdrain gravel support systems, backwashing capability, and air scour
3 distribution headers within the past fifteen (15) years.

4
5 **IS HEREBY REPLACED WITH THE FOLLOWING:**
6

- 7 C. Have constructed at least ten (10) multi-media, declining rate filters with backwashing
8 capability within the past fifteen (15) years. At least three (3) of the ten (10) filters shall
9 have included air scour systems.

- 10
11
12 2. ARTICLE 5 – PRE BID CONFERENCE, item 5.1: The MANDATORY Pre-Bid Conference will
13 be held on February 23, 2021 at 10:00 am.
14

15 **IN THE STATEMENT OF CONTRACTOR’S QUALIFICATIONS / QUESTIONNAIRE**
16

- 17 1. Second Paragraph, under COMPANY HISTORY, Item g., which previously read as follows:
18

- 19 C. Have constructed at least ten (10) multi-media, declining rate filters with corrugated
20 metal underdrain gravel support systems, backwashing capability, and air scour
21 distribution headers within the past fifteen (15) years.
22
23

24 **IS HEREBY REPLACED WITH THE FOLLOWING:**
25

- 26 C. Have constructed at least ten (10) multi-media, declining rate filters with backwashing
27 capability within the past fifteen (15) years. At least three (3) of the ten (10) filters shall
28 have included air scour systems.
29
30
31
32
33

34 ***The remainder of this page is intentionally blank***
35
36
37
38
39
40
41
42
43

1
2
3
4
5
6
7
8
9
10

END OF ADDENDUM NO. 1